

# Supplier Declaration of Conformity (SDOC)



(in accordance with ISO/IEC 17050-1:2004)

## SDoC Identification Number: NHPCPR.003

NHP Electrical Engineering Products (N.Z.) Ltd  
118a Carbine Road, Mt Wellington  
Auckland 1060  
New Zealand  
NZ Company No: 931377  
Telephone +64 9 276 1967  
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd  
43-67 River Street, Richmond  
Victoria 3121  
Australia  
A.B.N. 84 004 304 812  
Telephone +61 3429 2999  
www.nhp.com.au

### Product details:

#### Product model:

CPR24M250G, CPR24M2500  
CPR36M250G, CPR36M2500  
CPR48M250G, CPR48M2500  
CPR60M250G, CPR60M2500  
CPR72M250G, CPR72M2500  
CPR84M250G, CPR84M2500  
CPR96M250G, CPR96M2500

#### Description/Ratings:

Pole Capacity: 24, 36, 48, 60, 72, 84, 96  
Current Rating  $I_{nA}$ : 250A  
Main Switch: 250A  
Busbar Rating: 250A  
IP Rating: 66  
Short circuit rating  $I_{cw}$ : 6.5kA 1s (for higher ratings refer to NHP)  
Rated Diversity Factor RDF: 0.6 (63A)  
Rated Operational Voltage  $U_e$ : 230/400 – 240/415V 50 Hz  
Form of Separation: 2b  
Impact Rating: IK 10

### The products listed above is in conformity with the following Standard(s)/Normative Documents:

#### Standard/Document:

- AS/NZS: 61439.1:2016, Annex D Table D.1 List of design verification to be performed
- AS/NZS: 61439.2:2016, CL10 Design verification
- AS/NZS: 61439.3:2016, CL10 Design verification (Product is marked AS/NZS 61439.3)

#### Test reports/Certificates:

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
	Strength of Material and parts	10.2				
	Resistance to corrosion	10.2.2	✓			CE TR2945B
	Properties of insulating materials	10.2.3				
	Thermal stability	10.2.3.1				Assessed and deemed not required as enclosure is metallic
1	Resistance to abnormal heat and fire due to internal electric effects	10.2.3.2	✓			TUV50203205001 & TUV50227631001
	Resistance to UV radiation	10.2.4	✓			CE TR2945C
	Lifting	10.2.5				Assessed and deemed not required as there are no specific lifting points
	Mechanical impact	10.2.6	✓			TUV AU216R1D001
	Marking	10.2.7	✓			NHP202104-01

■ = Not allowed

# Supplier Declaration of Conformity (SDOC)




(in accordance with ISO/IEC 17050-1:2004)

**SDoC Identification Number: NHPCPR.003**

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
2	Degree of protection of enclosures	10.3	✓			TUV50093297001
3	Clearance	10.4	✓			NHP202105-08
4	Creepage Distances	10.4	✓			NHP202105-07
	Protection against electric shock and integrity of protective circuits	10.5				
5	Effective continuity between the exposed conductive part of the assemble and the protective circuit	10.5.2	✓			Tested and passed by TÜV Rheinland Australia, awaiting final test report No.
	Short circuit withstand strength of the protective circuit	10.5.3	✓	✓		TUV 50074477001 & TUV AU21SXHF001
6	Incorporating of switching devices and components	10.6			✓	NHP202103-07
7	Internal electrical circuits and connections	10.7			✓	NHP202103-08
8	Terminals for external conductors	10.8			✓	NHP202103-09
	Dielectric Properties	10.9				
9	Power-frequency withstand voltage	10.9.2	✓			NHP202103-02
	Impulse withstand voltage	10.9.3	✓			NHP202103-05
10	Temperature-rise limits	10.10	✓	✓		NHP202105-01 & NHP201908-01
11	Short-circuit withstand strength	10.11	✓	✓		TUV AU21878L001 & TUV AU21XD5M001 & TUV AU21BKZ0001 & TUV AU21NU7E001
12	Electro magnetic compatibility (EMC)	10.12				Not required, incorporated devices comply and installed to EMC requirements
13	Mechanical operation	10.13	✓			NHP202105-06
	Mechanical strength or fastening mean of enclosures	10.101	✓			NHP202104-02
	Fixing in position of pole fillers to comply IP2XC of 8.2.2	10.102	✓			NHP202104-03

■ = Not allowed

**Name:** Jamie Goddard  
**Position:** Product Manager—Distribution systems and Protection  
**Date:** 24/05/2021



**Signature of Authorised Person**