

Supplier Declaration of Conformity (SDOC)



(in accordance with ISO/IEC 17050-1:2004)

SDoC Identification Number: NHPCOE.004

NHP Electrical Engineering Products (N.Z.) Ltd
 118a Carbine Road, Mt Wellington
 Auckland 1060
 New Zealand
 NZ Company No: 931377
 Telephone +64 9 276 1967
 www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd
 43-67 River Street, Richmond
 Victoria 3121
 Australia
 A.B.N. 84 004 304 812
 Telephone +61 3429 2999
 www.nhp.com.au

Product details:

Product model:

COEACC2MELG
 COEACC3MELG
 COEACC21LG
 COEACC42LG
 COEACC63LG

Description/Ratings:

Pole Capacity: N/A, 21, 42, 63
 Current Rating I_{nA} : N/A
 Main Switch: N/A
 Busbar Rating: N/A
 IP Rating: 40
 Short circuit rating I_{cp} : N/A
 Rated Diversity Factor RDF: N/A
 Rated Operational Voltage U_e : 230/400 – 240/415V 50 Hz
 Form of Separation: N/A
 Impact Rating: IK 07

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

- AS/NZS: 61439.1:2016, Annex D Table D.1 List of design verification to be performed
- AS/NZS: 61439.2:2016, CL10 Design verification
- AS/NZS: 61439.3:2016, CL10 Design verification (Product is marked AS/NZS 61439.3)

Test reports/Certificates:

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
	Strength of Material and parts	10.2				
	Resistance to corrosion	10.2.2	✓			CE TR2945A-R1
	Properties of insulating materials	10.2.3				
	Thermal stability	10.2.3.1				Assessed and deemed not required as enclosure is metallic
1	Resistance to abnormal heat and fire due to internal electric effects	10.2.3.2	✓			TUV50203205001
	Resistance to UV radiation	10.2.4				Assessed and deemed not required as is for indoor applications
	Lifting	10.2.5				Assessed and deemed not required as there are no specific lifting points
	Mechanical impact	10.2.6	✓			TUV AU21W2IS001
	Marking	10.2.7	✓			NHP202104-01

☐ = Not allowed

Supplier Declaration of Conformity (SDOC)



(in accordance with ISO/IEC 17050-1:2004)

SDoC Identification Number: NHPCOE.004

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
2	Degree of protection of enclosures	10.3	✓			TUV500923299001
3	Clearance	10.4	✓			NHP202105-08*
4	Creepage Distances	10.4	✓			NHP202105-07*
	Protection against electric shock and integrity of protective circuits	10.5				
5	Effective continuity between the exposed conductive part of the assemble and the protective circuit	10.5.2	✓			Tested and passed by TÜV Rheinland Australia, awaiting final test report number*
	Short circuit withstand strength of the protective circuit	10.5.3	✓	✓		TUV 50074477001*
6	Incorporating of switching devices and components	10.6				Assessed and deemed not required as there are no included switching devices
7	Internal electrical circuits and connections	10.7				Assessed and deemed not required as there are no included electrical devices
8	Terminals for external conductors	10.8				Assessed and deemed not required as there are no included electrical devices (terminals)
	Dielectric Properties	10.9				
9	Power-frequency withstand voltage	10.9.2				Assessed and deemed not required as there are no included electrical devices
	Impulse withstand voltage	10.9.3				Assessed and deemed not required as there are no included electrical devices
10	Temperature-rise limits	10.10				Assessed and deemed not required as there are no included electrical devices
11	Short-circuit withstand strength	10.11				Assessed and deemed not required as there are no included electrical devices
12	Electro magnetic compatibility (EMC)	10.12				Assessed and deemed not required, incorporated installed devices comply with EMC requirements
13	Mechanical operation	10.13	✓			NHP202105-06
	Mechanical strength or fastening mean of enclosures	10.101	✓			NHP202104-02
	Fixing in position of pole fillers to comply IP2XC of 8.2.2	10.102	✓			NHP202104-03


* When used with NHP accessories

■ = Not allowed

Name: Jamie Goddard

Position: Product Manager—Distribution systems and Protection

Date: 24/05/2021



Signature of Authorised Person