

Applicant : CUBIC-Modulsystem A/S
Skjoldborgsgade 21
9700 Broenderslev
Denmark

Application Date : 2004-06-28

Order Number : 207501800-QUA/IND

Subject : type test of low-voltage switchgear and controlgear assemblies

Tradename : CUBIC

Type(s) : S225, S2000 and S7000


Arnhem, June 10, 2005

Manufacturer/ Production sites: CUBIC-Modulsystem A/S, Skjoldborgsgade 21
9700 Broenderslev, Denmark

Test Requirements : EN 60439-1:1999 / IEC 60439-1:1999 + A1:2004

The test results and the observations made during the tests have been recorded within this test report.

Tested by : C.C. Burger 

Checked by : H.L. Schendstok 

Contents

- Test description and test results
- Photograph(s)
- Test circuit diagrams
- Oscillograms
- Photographs
- Drawings

P/HLS

0247-05

© KEMA Quality B.V. All rights reserved.

Products may only be provided with a quality mark or put on the market as approved if KEMA Quality B.V. has explicitly granted the right to carry a quality mark.

KEMA Quality B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.

KEMA Quality B.V., Utrechtseweg 310, 6812 AR Arnhem, The Netherlands, PO Box 5185, 6802 ED Arnhem, The Netherlands. Website www.kema.com www.BuyerRisk.com Telephone: +31 26 3 56 20 00.
Telefax: +31 26 3 52 58 00.

Product information:

Low-voltage switchgear and controlgear assembly

Tradename	:	CUBIC
Product	:	Main Switchboard
Types	:	S225, S2000 and S7000
Short-circuit strength of busbar systems (Icw)	:	See table below

Ratings assigned by the manufacturer

Rated operational voltage (Ue)	:	415 V
Rated insulation voltage (Ui)	:	1000 V
Rated frequency	:	50 Hz
Degree of protection	:	IP54

Identification of the low-voltage switch- and controlgear assembly

The identification of the low-voltage switch- and controlgear assemblies is given on the attached photos, drawings and in the descriptions below.

COPY