

Test Report

TR 4600--088-001

Order No.: 0103761...63; 0104106...09

Customer: CUBIC-Modulsystem A/S
Skjoldborgsgade 21
DK-9700 Broenderslev

Manufacturer: see above

Specimen: Motor Control Centers

Type reference: CUBIC Modular System

Date of manufacture: October , 2001


Test specification: UL845 (February 15,1995) Fourth Edition

Tests: Short-circuit test; Section 24 (Bus section)
Short-circuit test; Section 25 (Units)
Dielectric voltage-withstand test; Section 24.7 and 25.7
Grounding and bonding; Section 19
Temperature test; Section 22
Dielectric voltage-withstand test; Section 23


Test result: passed

Number of pages (total): 279 (1 cover sheet, 246 documentation sheets, 32 enclosures)

Date of issue: December 18, 2001



Director Prüflaboratorium Bonn



The above-mentioned test results refer to the tested specimen only. No part of the present test report shall be copied or duplicated without prior written consent of Moeller's test laboratory in Bonn.



Moeller is member of ALPHA, Association for Testing and Certification of Low-Voltage Equipment.



The Test Laboratory Bonn Moeller GmbH has been listed in the ALPHA and LOVAG register of approved test laboratories with the registration number Ident Number D 01.